


Workplace Electrical Safety

Electrical Incidents: 2003 - 2018

Electrical Fatalities



Electrical Fatalities 2003 - 2018

54% of fatal electrical injuries occurred in the construction industry

18% increase in fatal electrical injuries between 2017 and 2018

9% of all electrical injuries in 2018 were fatal

3% of all workplace fatalities were cause by contact / exposure to electricity


Electrical Injuries

Electrical Injuries 2003 - 2018

310 electrical injuries occurred in the construction industry

29% decrease in electrical injuries between 2017 and 2018

4 the median number of days away from work due to electrical injury



OSHA's Top Electrical Violations of 2019

LOCKOUT / TAGOUT



OSHA - 29 CFR 1910.147
NFWA 70E - 120.1
Proper lockout/tagout (LOTO) practices and procedures safeguard workers from the release of hazardous energy.

PERSONAL PROTECTIVE & LIFESAVING EQUIPMENT: EYE & FACE PROTECTION



OSHA - 29 CFR 1926.102
NFWA 70E - 130.7(C)(3)
The employer shall ensure that each affected employee uses appropriate eye or face protection when exposed to eye or face hazards